



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20192898	Date:	December 18, 2019
Project Title:	ROYAL NUTRITION	Applicant:	
Location:	857 SW LEMANS LN, LEES SUMMIT, MO 64082		ADVANTAGE FIRE PROTECTION SYSTEMS INC
Type of Work:			404 B NW 11TH ST
Occupancy Group:	M		BLUE SPRINGS, MO 64015
Description:	CHANGE OF TENANT FOR RETAIL	Primary:	(816) 224-3400
	SALES OF NUTRITIONAL PRODUCTS - INCLUDES A		
	SMOOTHIE BAR		
Construction Type:	Type VB (Unprotected)		
Map Page:	215A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. (Informational Purposes)
Current annual inspection tag needed on riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.