

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190763  
Address: 4836 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, December 18, 2019

Corrective Action Required:

1	Misc	-Sidewalk and driveway not approved on record -Exterior not fully inspected at this time. Make sure the sewer tracer port is installed at grade level. Check water meter. Sewer manhole at front -Seal exterior wall penetrations -Sump pump discharge -Install secondary lock for slide door per security code -Install bedroom window cranks -Install 20 minutes fire-rated attic access in garage -Install security strike plate for all exterior doors
---	------	---

Comments: