

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192062  
Address: 4020 SW MERITAGE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Brandon Kalwei	Failed	Wednesday, December 18, 2019

Corrective Action Required:

1	Misc	Install and fix proper erosion control before any future inspections
---	------	--

**Comments:**