

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170401

Address: 3530 SW HOLLYWOOD DR, Unit:3, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Brandon Kalwei	Failed	Wednesday, December 18, 2019

Corrective Action Required:

1	Misc	209- missing uppers and backsplash cover plates . 206-missing uppers no backsplash, outlets & cover plates not set. 207-same as 206. 106-uppers same as 206,207. 108- lowers & uppers anti tip device on stove , kit counter outlets. Storage >>Center IT Room install metal sleeves to ceiling and secure on all low voltage and cables. >> Basement north end—ok 06- anti tip stove outlets and 1 upper. Electrical panel not Labeled. 08-no kitchen uppers & lower counters, electrical or plumb , sink, etc. No inspection of Kitchen Install all ranges and anti-tip devices. Complete all unfinished counter, uppers, lowers, back splash, spark rings on outlets & covers. Need to inspect roof top
---	------	---

Comments: