

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190129  
Address: 1924 NE CATALINA AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Thursday, December 19, 2019

Corrective Action Required:

1	Misc	-As-graded plot plan is required -Final grade, sod, downspout extensions -Exterior not inspected at this time -Provide afci protection per nec 2017 210.12; gfci for landry and dish washer outlets; tamper-resistant receptacles required -Label breaker -Lag deck ledger board
---	------	---

**Comments:**