

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191204  
Address: 1809 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Brandon Kalwei	Failed	Thursday, December 19, 2019

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- final grade, water discharge needs to be 36" from foundation, sod</li><li>- dependent on final grade, guard rail needs to be installed on front porch</li><li>- anti siphon devise set screw needs to be installed per code</li><li>- hot water discharge pipe needs to be cut back to code</li><li>-joist hanger on west side of unfinished basement needs to be nailed, missed on all rough</li><li>- as graded plot plan needs to be submitted and approved by front counter staff.</li><li>- electrical penetration on east side of house needs to be sealed</li></ul> |
|---|------|--|

Comments: