

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183200
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Thursday, December 19, 2019

Corrective Action Required:

1	Misc	RESOLVE FIRE DEPARTMENT ISSUES
---	------	--------------------------------

Corrective Action Required:

2	Misc	MIRROR AT PUBLIC RESTROOM EXCEED MAXIMUM 40" HEIGHT
---	------	---

Corrective Action Required:

3	Misc	ROOFTOP INSPECTION: - SUBJECT TO INSPECTION WITH NO SNOW COVER - ELECTRICAL RECEPTACLE NOT FOUND - PIPE NOT PAINTED - NUMBER UNITS AND DISCONNECTS PER PANEL LABELS
---	------	---

Corrective Action Required:

4	Misc	ELECTRICAL PANEL SCHEDULES NOT ACCURATE
---	------	---

Corrective Action Required:

5	Misc	BREEZEWAY AT NORTH NOT READY FOR FINAL INSPECTION.
---	------	--

Corrective Action Required:

6	Misc	OBTAIN APPROVAL FROM: - WATER DEPARTMENT - SITE CIVIL DIVISION - PLANNING DIVISION
---	------	---

Comments:

