

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190262
Address: 4517 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Thursday, December 19, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- garage door needs to be self closing/latching, not latching from halfway point- rear sliding doors need to have second locking devise installed- master shower needs to be complete- 1 joist in unfinished basement need to be fire protected- plumbing in basement bathroom needs to be complete- secure electrical meter conduit below meter to foundation- joist hanger on south side of deck needs to nailed completely- seal exterior lights and penetrations
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: