

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20190763
Address: 4836 NE JAMESTOWN DR, LEES SUMMIT, MO 64064
Inspected On: Thursday, December 19, 2019
Inspected By: Khanh Nguyen
Expiration Date: 1/20/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, December 19, 2019

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Exterior not fully inspected at this time. Make sure the sewer tracer port is installed at grade level. Check water meter. Sewer manhole at front |
| | | -Install security strike plates for all exterior doors |