

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192982
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, December 20, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, &
VENT PIPING AT:

**4" PVC BUILDING DRAIN ON (3.3) FROM 5' OUTSIDE B/L AT(A) TO 3.3/D.6;
THEN 20' N & S;**

ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312 /
IRC P2503.5.1

Comments: