

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192296
Address: 1901 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, December 20, 2019

Corrective Action Required:

1	Misc	Provide solid blocking at sheathing breaks front bedroom Provide GFCI receptacle within 25' of exterior HVAC equipment Seal exterior penetrations under windows master bedroom
---	------	--

Comments: