

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190274

Address: 2861 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Friday, December 20, 2019

Partial Correction:

1 Misc

2-HR FIRE BARRIER WALL:

-1ST FL WALL FROM H.8/7 TO J.5/7-1ST LAYER ON BOTH SIDES OK. NORTH SIDE
2ND LAYER OK.

-WALL IN ELECTRICAL RM-2ND LAYER OK

-H.2/7 TO H.8/7-2ND LAYER OK

ELEVATOR SHAFT WALL: 1" GYP BOARD INSTALLATION-OK; OUTER LAYER OF
1ST AND 2ND FL-OK; ELEVATOR EQUIPMENT RM WALL IN PROGRESS

Comments: