

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20173051  
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Failed	Friday, December 20, 2019

Partial Correction:

1	Misc	-ELEVATOR SHAFT WALL: 3RD FL N&W WALL 1" GLASS BOARD-OK -MECHANICAL SHAFT WALL: 3RD FL W WALL 1" GLASS BOARD-OK  2ND FL N,E,&W WALL AND 3RD FL EAST WALL 1" GLASS BOARD NOT SCREWED PER WALL DESIGN
---	------	--

**Comments:**