

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20183200  
**Address:** 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081  
**Inspected On:** Friday, December 20, 2019  
**Inspected By:** John Borns  
**Expiration Date:** 12/27/2019

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Friday, December 20, 2019

**Corrective Action Required:**

3	Misc	ROOFTOP INSPECTION: INSTALL IN-USE ELECTRICAL RECEPTACLE THAT CAN BE OPENED AS DESIGNED
---	------	---

**Corrective Action Required:**

4	Misc	IDENTIFY ALL CIRCUITS. LABELING OF ELECTRICAL CIRCUIT BREAKERS: EACH BREAKER MUST BE LABELED WITH REFERENCE TO SPECIFIC SPACE(S), APPLIANCE OR EQUIPMENT SERVED. MUST BE LEGIBLE; SPECIFIC. NO DITTO MARKS OR CONTINUATION SYMBOLS FOR INDIVIDUAL BREAKERS. LABEL UNUSED BREAKERS "SPARE".
---	------	--

**Corrective Action Required:**

5	Misc	BREEZEWAY AT NORTH NOT READY FOR FINAL INSPECTION.
---	------	--

**Corrective Action Required:**

6	Misc	OBTAIN APPROVAL FROM: - WATER DEPARTMENT
---	------	---

- SITE CIVIL DIVISION
- PLANNING DIVISION