

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192495

Address: 2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Khanh Nguyen	Failed	Monday, December 23, 2019

Corrective Action Required:

1	Misc	SHEAR WALLS: -NAIL SHEATHING @ 2" OC -AT SEAMS, BLOCK AND NAIL @ 2" OC
---	------	--

**Comments:**