

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193619

Address: 668 SE BAYBERRY LN, Unit:105, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Failed	Monday, December 23, 2019

Corrective Action Required:

1	Misc	Secure MC within 12" of box. Sheathing needs to be extended down into clamp of the dryer box.
---	------	-----------------------------------------------------------------------------------------------

Comments: