

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192818  
Address: 4064 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Residential</b>	Khanh Nguyen	Partial	Monday, December 23, 2019

**Corrective Action Required:**

1	Misc	-Based on the conversation with the foreman there, the basement was filled with AB3. Slab reinforcement was #4@24" on center. -Garage floor rebars not epoxied into the foundation wall. No plan on site
---	------	---

**Comments:**