

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193057
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Inlets Clean	John Jackson	Partial	Tuesday, December 24, 2019

Informational:	
1 Misc	Contractor began the installation of storm boxes B1 and B2.
Informational:	
2 Misc	
Informational:	
3	Contractor began installation of storm inlet A1 as per plans.
Informational:	
4 Misc	Contractor installed Inlet Box A2

Comments: