

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172503  
Address: 205 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Failed	Friday, December 27, 2019

Corrective Action Required:

1	Misc	Approved for TCO pending the the following items are corrected and inspected when completed.  - seal all exterior light pentraions. -- install anti-siphon on hose bib Fire sprinkler room.
---	------	--

**Comments:**