

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191899
Address: 1821 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Brandon Kalwei	Failed	Friday, December 27, 2019

Corrective Action Required:

1	Miscellaneous Correction	Repair and maintain erosion control at front and sides of house. Clean up street and curbs of debris and mud
---	--------------------------	--

Comments: