

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192062
Address: 4020 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Brandon Kalwei	Failed	Friday, December 27, 2019

Corrective Action Required:

1	Misc	Not enough PSI in pressure gauge, need 10 psi for 15 minutes minimum
---	------	--

Comments: