

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20170788

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Monday, December 30, 2019

Corrective Action Required:

1	Misc	-APPROVAL REQUIRED FROM: PLANNING, FIRE, FIELD SERVICE -SUBMIT FINAL SPECIAL INSPECTION LETTER -PROTECT GROUNDING CONNECTION TO ROD. -PROTECT THE SERVICE EQUIPMENTS AND GAS -FLOOR DRAIN NOT INSTALLED IN MECHANICAL RM -POST AVAILABLE FAULT CURRENT PER 110.24 AND ARC-FLASH HAZARD WARNING PER 110.16
---	------	--

**Comments:**