

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20191464
Address: 1112 NE GOSHEN CT, LEES SUMMIT, MO 64064
Inspected On: Monday, December 30, 2019
Inspected By: Khanh Nguyen
Expiration Date: 1/30/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Monday, December 30, 2019

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -As-graded plot plan is required
-Lower sewer manhole to final grade
-Lag deck ledger board through the spacers
-Window located adjacent to stair and less than 36" above stair shall be tempered safety glass window
-Provide afci breaker for kitchen hood (NEC210.12) |
|---|------|--|