

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192061
Address: 4717 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, December 31, 2019

Corrective Action Required:

1	Misc	-Install door frames per security code **Install door frame; install security blocking; fill in any gap behind hinges and strike plate side with solid wood -Fb basement wall from joist space and fur-down ceiling space **wall still not fireblocked from ceiling space
---	------	--

Comments: