

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190494
Address: 2512 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Failed | Tuesday, December 31, 2019 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Provide two 3" screws hinges & strike plate deck & basement doors Provide back flow / lawn irrigation permit Provide Sheetrock under stairway unfinished basement Provide 2" clearance wood siding to concrete front porch Repair or replace GFCI receptacle at basement door on patio won't trip or reset |
|---|------|--|

Comments: