

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182613
Address: 905 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, January 02, 2020

Partial Correction:

1 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT STAIRS:

STAIR #1:

1ST FLOOR: WELL FACE + BACKSIDE ABV CLG: **1ST & 2ND LAYERS;**

STAIR #2:

1ST FLOOR: WELL FACE + BACKSIDE ABV CLG: **1ST & 2ND LAYERS;**

Partial Correction:

2 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT ELEVATOR:

PRE-ROCK @ BACKSIDE ABV CLG:

1ST FLOOR: **1ST & 2ND LAYERS;**

2ND FLOOR:

3RD FLOOR:

4TH FLOOR:

Comments: