

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20173051  
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Thursday, January 02, 2020

Partial Correction:

1	Misc	-ELEVATOR SHAFT WALL-OK: 3RD FL N&W&E WALL AND 2ND FL N,W,&E WALL 1" GLASS BOARD -MECHANICAL SHAFT WALL-OK: 3RD FL W WALL 1" GLASS BOARD-OK -NORTH WALL MECHANICAL SIDE OK TO COVER ONLY. 1" GLASS.
---	------	--

**Comments:**