

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20170401

Address: 3530 SW HOLLYWOOD DR, Unit:3, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Brandon Kalwei	Failed	Friday, January 03, 2020

Corrective Action Required:

1	Misc	209- missing uppers and backsplash cover plates . 206-missing uppers no backsplash, outlets & cover plates not set. >> 207-same as 206. > 108- lowers & uppers anti tip device on stove , kit counter outlets.  >> 06- anti tip stove outlets and 1 upper. 08-no kitchen uppers & lower counters, electrical or plumb , sink, etc. No inspection of Kitchen Install all ranges and anti-tip devices. Complete all unfinished counter, uppers, lowers, back splash, spark rings on outlets & covers.  Room 106 ok to occupy
---	------	--

Comments: