

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192613
Address: 409 SE MILL CREEK CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Passed	Monday, January 06, 2020

Informational:

1 Misc

Insepected all joists, joist hangers, ledger connection to house, joist to beam connection, all ok to cover. Call in when framing and electrical is done to be inspected.

1/6/2020 inspection - ok to cover and call in for final inspection

Comments: