

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192061
Address: 4717 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Monday, January 06, 2020

Corrective Action Required:

1	Misc	-Fb basement wall from joist space and fur-down ceiling space **wall still not fireblocked from ceiling space,, wal and ceiling not fire stopped. Need to block vertical to horizontal at drop ceiling height from wall. north side of basement , dead space at shower needs fire stopped vertical to horizontal also.
---	------	--

Comments: