

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192061  
Address: 4717 NE SARATOGA CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Mark Harding	Failed	Monday, January 06, 2020

Corrective Action Required:

2	DCM5 Erosion Control	REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.
---	----------------------	---

Swale at rear yard needs to be Corrected and silt fence established. silted in swale needs to be cleaned out and approved by Steve Robbins prior to sod.

Contact Steve Robbins or Mark Harding

**Comments:**