

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191322  
Address: 2919 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Brandon Kalwei	Failed	Monday, January 06, 2020

Corrective Action Required:

1	Misc	Erosion control needs to be fixed and street/curb needs to be cleaned if all mud and debris - seal exterior light fixtures - two locking devices needed for back sliding door - underneath stair stringers in unfinished basement area need to be fire protected - as graded plot plan needs to be submitted and approved by front counter staff - final grade, side, water discharge needs to be 36" from foundation
---	------	--

Comments: