

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20192495	Date:	January 06, 2020
Project Title:	KANSAS CITY SURGICAL AND DENTAL	Applicant:	
Location:	2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064		
Type of Work:			AEGIS FIRE PROTECTION LLC
Occupancy Group:	B		11936 W 119TH ST
Description:	NEW DENTAL SURGERY BUSINESS		OVERLAND PARK, KS 66213
Construction Type:	Type VB (Unprotected)	Primary:	(913) 825-0343
Map Page:	175R		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test and a water flow test.

2. (ACTION REQUIRED)

Provide a 4 inch Storz connection for the FDC.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**