

# Inspection Summary

Permit #: PRPWFC20173611, Public Works Infrastructure Permit - Commercial

Village at View High On-Site Infrastructure

Address: 3390 NW VILLAGE PARK DR, LEES SUMMIT, MO 640813391 NW VILLAGE PARK DR, LEES SUMMIT, MO 64081245 NW KESSLER DR, LEES SUMMIT, MO 64081201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer Construction Inspection	Steve Robbins	Passed	Monday, January 06, 2020

Informational

1 The water dept. ran the camera test and found a sag and an invert that needed to be corrected. The sag was between MH 27-259 and MH 27-260. The Sag has been repaired and the water dept. agreed to inspect it before the 30 days and then inspect after 30 again so we will be able to give them substantial completion for the off-site project. I spoke with Brent today and they will come out again is 30 day to inspect, if it is not good they will have to make corrections again. If they do not fix the problem we will hold up TCO on any buildings that do not have one yet.

Resolved

2 The water dept. ran their cameral through again and they said everything is good. I am passing all the sanitary as of now.

Comments: