

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191159
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|---------------------------|
| Rough Electrical Inspection - Commercial | John Borns | Partial | Tuesday, January 07, 2020 |

Partial Correction:

| | | |
|---|------|---|
| 1 | Misc | UFER GROUND JUMPER TERMINATED TO WALL RE-BAR AT WEST FOUNDATION WALL; |
|---|------|---|

Comments: