

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20191083  
Address: 109 SW MEADOWBROOK DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Brandon Kalwei	Failed	Tuesday, January 07, 2020

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>- Final grade, sod, splash blocks</li><li>- sidewalk approval and needs poured</li><li>- guard rail needs to be installed on front porch, east side</li><li>- dish washer water line needs hammer arrestor installed</li><li>- dishwasher drain line needs to be secured above connection to garbage disposal</li><li>- Landing needed for the deck stairs</li><li>- label garage electrical panel</li><li>- window adjacent to back door needs to be tempered</li><li>- anti siphon devise screw needs to be installed correctly</li><li>- sump pump discharge pipe needs to be cut back to code</li></ul> |
|---|------|---|

**Comments:**