

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191770
Address: 2861 NE INDEPENDENCE AVE, Unit:101, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Wednesday, January 08, 2020

Partial Correction:

1 Misc

2-HR FIRE BARRIER:

- ELECTRICAL RM-2ND LAYER OK
- SPRINKLER RM-1ST LAYER OK
- COLUMN G WALL: 2ND LAYER BOTH SIDES OK
- WALL LINE 7 FROM H.8 TO J.5-2ND LAYER OK WITHIN SOFFIT, 2ND LAYER OK BELOW SOFFIT

- : 2nd layer type X hallway at north stairwell screw patten OK
- : Area C OR 5 north & west walls 1 hr wall 1 layer type X OK
- : Area B 2nd layer typeX , 1st layer type X vestibule 1170 OK

1-HR WALL:

- RM 1171-1174-OK

SMOKE WALL: SEALING AT TOP IN PROGRESS!
Area B. Complete

Comments: