

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192732
Address: 2921 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, January 08, 2020

Corrective Action Required:

1	Misc	ELECTRICAL PANEL NEEDS TO BE BONDED
---	------	-------------------------------------

Comments: