

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190274
Address: 2861 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Failed	Thursday, January 09, 2020

Partial Correction:

1 Misc

IN-WALL OK:

- RESTROOMS RM 1003/1004/2001/2002, WALL OUTSIDE RESTROOM 1003&1004
- COL G 2HR FIREWALL FROM 7 TO 2.3
- WEST EXTERIOR WALL (EXOS TENANT)

Corrective Action Required:

2 Misc

NORTH LOBBY RESTROOM PROVIDE COVERS FOR BOXES ABOVE DOOR, SOUTH OK

Comments: