



### **PLANS REVIEW CONDITIONS**

Permit No: PRCOM20193616

Project Title: PEACE PAWS

Location:

845 SW LEMANS LN, LEES SUMMIT, MO 64082

Type of Work:

Occupancy Group: B

Description: TENANT FINISH FOR DOG  
GROOMING BUSINESS

\*\*drawings are in plan review file

Construction Type: Type VB (Unprotected)

Map Page: 215A

Date: January 09, 2020

Applicant:

<NO CONTACT NAME AVAILABLE>

<NO CONTACT INFORMATION AVAILABLE>

<NO CONTACT NAME AVAILABLE>

<NO CONTACT INFORMATION AVAILABLE>

BILL IRELAND SECURITY INC  
15227 BROADMOOR STREET  
OVERLAND PARK, KS 66223

Primary: (913) 897-7518

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule alarm testing.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**