

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20192898	Date:	January 09, 2020
Project Title:	ROYAL NUTRITION	Applicant:	
Location:			
857 SW LEMANS LN, LEES SUMMIT, MO 64082		BILL IRELAND SECURITY INC	
Type of Work:		15227 BROADMOOR STREET	
Occupancy Group:	M	OVERLAND PARK, KS 66223	
Description:	CHANGE OF TENANT FOR RETAIL	Primary:	(913) 897-7518
SALES OF NUTRITIONAL PRODUCTS - INCLUDES A			
SMOOTHIE BAR			
Construction Type:	Type VB (Unprotected)		
Map Page:	215A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule alarm testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.