

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192706  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Thursday, January 09, 2020

Partial Correction:

1 Misc

OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING LOCATIONS:  
11/C; 11/D; 11/E; 11/F; 11/G; 11/H; 10/C; 10/D; 10/E; 10/F; 10/G; 10/H; 9/C;  
9/D; 9/E; 9/F; 9/G; 9/H; 8/C; 8/D; 8/E; 8/F; 8/G; 8/H; 7/C; 7/D; 7/E; 7/F; 7/G;  
7/H; STEP FOOTING FROM FTG E/8 EAST TO ELEVATOR PIT SLAB; 6/C; 6/D; 6/E;  
6/F; 6/G; 6/H; 5/C; 5/D; 5/E; FOOTINGS AND ELEVATOR PIT SLAB ON (5) FROM  
(F) TO (G.2); H/5; [4.5/C; 4.5/D; 4.5/E; 4.5/F; 4.3/C; 4.3/D; 4.3/E; 4.3/F; 4/C; 4/D;  
4/E; 4/F; 4/G; 4/H; 3/C; 3/D; 3/E; 3/F; 3/G; 3/H; 2/C; 2/D; 2/E; 2/F; 2/G; 2/H;  
B/11; B/10; B/9; B/8; A/8; B/2; B/3; B/6; B/7; **B/4; B/4.3; B/4.5; B/5; A/4.1;**  
**A/4.3; A/4.5; A/5**

Partial Correction:

2 Misc

OK TO POUR WHEN READY WALL FOOTING & INTEGRAL COLUMN FOOTINGS  
AT: A'/11.2 CCW TO A/8.5; A/8.5 TO 7.5/A'; 7.3/A.1 CCW TO 3.9/A; A/3.3 CCW  
TO A'/1.5; A'/11.2 TO 13/A' TO 12/E.5; UFER GROUNDING JUMPER AT 12.7/A.5;  
12/E.5 TO I/12 TO I/9.1; I/9.1 to I/6.3; I/6.3 TO I/4.7; I/4.7 TO I/2; I/2 TO 1/I TO  
1/D.7;

**Comments:**