

Inspection Summary

Permit #: PRSITE20192792, Development - Site

KANSAS CITY SURGICAL AND DENTAL

Address: 2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line - Hydrostatic Test	John Jackson	Passed	Thursday, January 09, 2020

Informational

1 The hydrostatic test for the fire line was done at 200 for 2hrs. and has now passed.

Comments: