

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182611
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, January 09, 2020

Partial Correction:

1	Misc	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELLS INSIDE FACE & SPACES BETWEEN JOISTS AT BACKSIDE:
---	------	--

EAST STAIRWELL #1:
BASEMENT LEVEL: 1ST LAYER; 2ND LAYER
1ST FLOOR: 1ST LAYER; 2ND LAYER
2ND FLOOR: 1ST LAYER;
3RD FLOOR:
4TH FLOOR:

WEST STAIRWELL #2:
BASEMENT LEVEL: 2 LAYERS
1ST FLOOR: 1ST LAYER; 2ND LAYER
2ND FLOOR: 1ST LAYER;
3RD FLOOR:
4TH FLOOR:

Partial Correction:

2	Misc	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT:
---	------	--

BACKSIDE BETWEEN TRUSS JOISTS:

BASEMENT LEVEL: 2 LAYERS
1ST FLOOR: 1ST LAYER; 2ND LAYER
2ND FLOOR: 1ST LAYER;
3RD FLOOR:
4TH FLOOR:

Comments: