

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192982  
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                               | Inspector: | Outcome: | Date:                       |
|-----------------------------------------------------------|------------|----------|-----------------------------|
| <b>Underground Electrical<br/>Inspection - Commercial</b> | John Borns | Partial  | Friday, January 10,<br>2020 |

Partial Correction:

1 Misc

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL SYSTEM AT FOLLOWING LOCATIONS: ONE 1" FROM (1) TO (2); TWO 1" (2) TO (3); ONE 1" FROM (4) TO (5); THREE 1" FROM (2) TO (6); TWO 1" FROM (6) TO (7); TWO 1" FROM (6) TO (8); FIVE 1" FROM (2) TO (6); TWO 1" FROM (6) TO (13); ONE 1" FROM (7) TO (9); ONE 1" FROM (10) TO (12); ONE 1" FROM (9) TO (12); ONE 1" FROM (X) TO (Y); ONE 1" FROM (X) TO (Y); FOUR 1" FROM (X) TO (Y); ONE 1" FROM (13) TO (16); TWO 1" FROM SW CORNER OF BLDG TO (18); **ONE 1" FROM (18) TO (19); SEVEN 4", ONE 1-1/4", THREE 1" FROM MDP TO EXTERIOR THEN NORTH TO SERVICE EQUIPMENT AT C/2;**

Comments: