




STAND Structural Engineering Inc
8234 Robinson Street
Overland Park, KS 66204
(913) 214-2169


Date: 01/09/2020
To: Billy Barnard (Signature Builders)
From: Paul Spears, PE
Subject: Comments on Failed Inspection at
2921 NW Thoreau Drive (Permit #PRRES20192732)

Dear Mr. Barnard,

The following walls do not need to be 2x6 walls, 2x4 are acceptable.



FROM S101



Please let us know if we can be of further assistance.

Sincerely,

Paul Spears
Paul Spears, PE



01/09/2020