

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192443
Address: 2915 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Friday, January 10, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">-properly nail trusses to truss hangers, east wall in office/flex room- secure gas line to fire place- secure fireplace to framing- anchor beam posts throughout house- proper washer needs to be installed on east side hold down bolt in garage- garage portal straps need to be installed- hurricane straps missing on south side, second floor- vent pipe above bedroom #4 not being properly supported- double joist hanger needed, north side of basement |
|---|------|---|

Ok to insulate

Comments: