

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193404
Address: 855 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Failed	Monday, January 13, 2020

Corrective Action Required:
1 Misc -MOST OF THE FOOTING IS LESS THAN 36" BELOW GRADE, WITH SOME PARTS OF THE FOOTING ARE AROUND 25" BELOW GRADE. ALTHOUGH MUCH OF THE FOOTING IS LOCATED ON SOLID ROCK, HAVE ENGINEER ADDRESS THIS

Comments: