

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192982  
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	Michael Harkins	Partial	Tuesday, January 14, 2020

Partial Correction:

1	Misc	OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: 4" PVC BUILDING DRAIN ON (3.3) FROM 5' OUTSIDE B/L AT(A) TO 3.3/D.6; D.6/3.3 TO D.6/5.8; D.6/3.3 TO D.7/1.2; 1.45/D.6 TO G/9; 1.2/D.6 TO 1.2/F.9; ONE 4"/3" FROM 1.2/F.9 TO H.4/5.1; ONE 4" SAN & ONE 4" GW FROM 5' O/S B/L @ F.1/11 TO F.1/9.4 TO 9.4/C.6;  ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312 / IRC P2503.5.1
2	Misc	Grease line & sanitary sewer 4" main G10 to F10 OK to cover

**Comments:**