



1100 W Cambridge Circle Drive, Suite 700  
Kansas City, Kansas 66103  
913.627.9040

## DAILY FIELD REPORT

CLIENT: Pearl Real Estate Company  
919 N East Street  
Indianapolis, Indiana 46202

PROJECT: Summit of West Pryor  
Apartments  
Lee's Summit, Missouri

ATTN: Brad Richey

DATE: 12/26/19

WEATHER: Overcast

CFS  
PERSONNEL: M. Simpson

TEMPERATURE: 35-50

REPORT #: 19-1125-dr- 34

---

### TYPE OF SERVICE BEING PERFORMED

**CONCRETE** REINFORCING STEEL

**DEVIATION FOUND: NO**

**MASONRY** GROUT

**DEVIATION CORRECTED:**

**MASONRY** REINFORCING STEEL

**ORIGINAL DEVIATION DATE:**

---

### WORK ACCOMPLISHED THIS DATE:

- Inspected reinforcing steel placement for 12 line/B.2 to E
- Reinforcing steel verified to be in compliance with plans and specifications.